

- 1. Ramp cross slopes and landing slopes should not exceed 2%.
- 2. Ramps shall be flush at the gutter flow line.
- 3. Construction of Type B ramps is preferred where both sidewalks are set back from the curb by an earth strip.
- 4. Curb Ramps are required with all curb types.
- 5. Detectable warning strips shall consist of a 24" x [Ramp Width] truncated-dome style surface. Color shall be Federal Yellow.
- 6. Construction of Type C ramps is allowed only where site conditions preclude contruction of Type A or B ramps; obtain Engineer's approval before constructing Type C ramps.

AutoCAD: Curb Ramp - 2006 Rev.dw

PAGE NO:



CURB RAMP DETAILS FOR ARTERIAL STREETS

CITY OF PULLMAN ENGINEERING DIVISION

ADOPTED: April 8, 2008